

Date received	Date closed	Issue	Type	Method	Detail	Response	Status
10/1/2024	10/1/2024	Lights on at night	Complaint	Phone	Lights on at night from wind farm	Light was switched off and PB installed sensor lights at O&M building to limit light pollution at night	Closed
11/6/2024	12/06/2024	TV/Radio interference	Complaint	Phone	No Channel 7 and 9 TV reception	PB Contractor investigated and no issue with retransmitter was detected. Spoke with complainant, who said that the issue resolved over night.	Closed
20/11/2024	20/11/2024	TV/Radio interference	Complaint	Phone	No TV reception	PB sent a contractor to visit the health care facility. Facility's own antennae was faulty, not as a result of the re-transmitter.	Closed
21/11/2024	21/11/2024	TV/Radio interference	Complaint	Phone	No TV reception	Upgrade works undertaken in previous week. TV receptor unit needed to be reset.	Closed